



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000014988

KGN-OLK-024-2024

TENDER FOR SUPPLY OF SUBMERSIBLE PUMPS FOR OLKARIA II POWER STATION.

(Youth Enterprise)

Dated: 19th April, 2024

Clarification No.1.

In accordance with the **Tender for Supply of Submersible Pumps for Olkaria II Power Station**, KenGen issues a **Clarification No.1** as follows:

	BIDDERS CLARIFICATION	KenGen’s RESPONSE
1.	kindly provide guidance on any potential flexibility regarding the temperature range for the submersible pumps? Additionally, if there are any specific considerations or alternative options that have been identified to address this challenge	The pump should be applicable for pumping geothermal condensate of temperature range of between 60°C to 90°C.
2.	Please see the following options and clarify on the suitable option; Option 1- STGC040-125-CC <ul style="list-style-type: none"> • Suitable for sump installation • Sump depth Required? • Partially submersible • Meets temperature requirement and resistant to corrosive. Option 2- KRTK 65-253/114UEG <ul style="list-style-type: none"> • Suitable for completely submersed installation. • Installation depth required? • Does not meet the temperature requirements. 	Refer to section V of the Tender document on technical requirements. The pump should be fully submerged with a capability to handle geothermal condensate of specified temperature and head

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....