



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000014839

KGN-OLK-021-2024

TENDER FOR SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF 2.5MVA EMERGENCY DIESEL GENERATOR AND ACCESSORIES FOR OLKARIA II POWER STATION.

(Open National)

Dated: 19th April, 2024

Clarification No.4.

In accordance with the **Tender for Supply, Installation, Testing, and Commissioning Of 2.5MVA emergency Diesel Generator and Accessories for Olkaria II Power Station**, KenGen issues a **Clarification No.4** as follows:

	BIDDERS CLARIFICATION	KenGen’s RESPONSE
1.	I am writing to kindly request for clarification on the exact sizing in sq.mm of the MV cable	The MV cable sizes are based on the design calculations as stipulated in section 1.3.7 (a).

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.4

We, the undersigned hereby certify that the Clarification No.4 is an integral part of the document and the alterations set out in clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....