



KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-BDD-09-2021

TENDER FOR SUPPLY AND INSTALLATION OF TWO WIND LIDAR WEATHER STATIONS.

(Open International)

27th October 2021

Clarification No. 3

In Accordance with the “Tender for Supply and Installation of Two Wind Lidar Weather Stations.” KenGen hereby issues **Clarification No.3**

NO.	BIDDER'S QUESTION	KENGEN'S RESPONSE
1	Would it be possible for a company to take part in this tender (be the lead tenderer) and use a subcontractor who has attended the mandatory site visit? (In this case the company that is the lead tenderer did not attend the site visit).	The bidding company Must have attended the Mandatory site visit.
2	Given that the tender has been extended with a month, would it be possible to host another opportunity for a site visit (for companies that missed the initial site visit)?	The site visit was Mandatory as stated in the tender document and the second site visit request has been declined.
3	<p>There are several LIDAR models available on the market. They are differentiated by external testing and are typically:</p> <ul style="list-style-type: none">-Not classified by DNV-DNV Stage 2 bankable device-DNV Stage 3 bankable device (most bankable) <p>The LIDAR specifications in the tender documents <u>do not</u> specify DNV stage 2 or 3 requirements. If this is not specified, it is assumed that less bankable LIDARS (stage 2 or even not classified) may be used in bids? Please advise.</p>	The Lidar must be a DNV GL stage 3 Lidar and must satisfy IEC 61400-12-1 classification requirements.

ACKNOWLEDGEMENT OF CLARIFICATION NO.3

We, the undersigned hereby certify that the Clarification is an integral part of the document and the alterations set out in clarification has been incorporated in the Tender for Proposal.

Tenderer.....

Signed.....

Dated.....