



KenGen

KENYA ELECTRICITY GENERATING COMPANY LIMITED PLC

TENDER No. KGN-OLK-017-2025

**TENDER FOR SUPPLY AND INSTALLATION OF GRAVITY FLOW, DOUBLE DEEP AND
SELECTIVE PALLET RACKS FOR OLKARIA IV AND WELLHEADS WAREHOUSE.**

(Reserved for Women Enterprises)

Dated: 6th May, 2025

CLARIFICATION NO. 3

In accordance with the **Tender for Supply and Installation of Gravity Flow, Double Deep and Selective Pallet Racks for Olkaria IV and Wellheads Warehouse**, KenGen issues a **Clarification No. 3** as follows:

	BIDDERS CLARIFICATION	KenGen's RESPONSE
1	Drawing or layout or simple sketch of these all systems, like on the gravity racks	See Addendum No. 2
2	Pallet dimensions – width x depth x loaded height	1.2 x 1.0 x 1.0 m
3	Building drawings (in plan and in elevation)	Refer to Item. 1
4	Layout configuration of the racking	Refer to Item. 1
5	Number of lanes required for the Gravity-Flow racks	Refer to Addendum No. 2
6	Photos of the pallets to be used in the systems (to ensure compatibility)	Refer to Item. 2
7	What is the clear usable height in the areas where the racking will be installed?	The available head is 9m
8	What is the required aisle width for the forklift trucks for the selective pallet racking and double deep pallet racking?	3.6m
9	When is this project required to be completed?	Tenders shall remain valid for the Tender Validity period specified in the TDS.
10	Has the warehouse where these racks will be installed already been constructed?	Yes
11	Extension request for tender closing date	Refer to Addendum No. 2
12	Clarification on the coating of the material.	Refer to Addendum No. 2



KenGen

TENDERER'S ACKNOWLEDGEMENT OF CLARIFICATION NO.3

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification has been incorporated in the tender proposal.

Signed

Tenderer

Date.....