



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-HYD-034-2024

RFx: 5000015548

TENDER FOR A SUBMERSIBLE DEWATERING PUMP FOR KAMBURU POWER STATION.

(Reserved for Youth Enterprises)

21<sup>st</sup> June, 2024

ADDENDUM NO.1

In accordance with the “*Tender for a Submersible Dewatering Pump for Kamburu Power Station,*” KenGen hereby issues, **Addendum No.1**

**3. SCOPE OF WORK**

3.1. Submersible Dewatering Pump requirement

Procuring entity Initial requirement	Procuring entity revised requirement	Suppliers Offer
3.1.5 The pump shall have the capacity to deliver 684m <sup>3</sup> /h at 24m head	3.1.5 The pump shall have the capacity to deliver <b>over 400M<sup>3</sup>/h</b> of water at 24m head.	

**ACKNOWLEDGEMENT OF ADDENDUM NO.1**

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....