



KENYA ELECTRICITY GENERATING COMPANY PLC

TENDER FOR SUPPLY OF OLKARIA II THREE PHASE, 3.3Kv 400KW INDUCTION MOTOR (HOTWELL MOTOR)

KGN-GDD-218-2021

Date: 25th January 2022

CLARIFICATION NO.3

In accordance with the **TENDER FOR SUPPLY OF OLKARIA II THREE PHASE, 3.3Kv 400KW INDUCTION MOTOR (HOTWELL MOTOR)**, KenGen hereby issues Clarification No.3

No	Issue	Clarification
I	Attached in the email are datasheets for the Bently Nevada Vibration Monitor – 1900/65A and 1900/27 . Kindly advise/provide us with the Exact Model No. and Serial No. of the unit you have at site.	1900/65A Partno: 172323-01 S No:07J008YT 1900/27-01 S NO:0100WPD The above information is what is available on site and we urge all bidders to follow the technical specifications and provide the appropriate spare as this is a direct spare replacement to the existing one and we intend to have no modifications in matters of the process connection.

ACKNOWLEDGEMENT OF CLARIFICATION No.3

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date