



KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000009961

KGN-CW-04-2022

TENDER FOR SUPPLY, INSTALLATION AND COMMISSIONING OF AUTOMATIC VOLTAGE STABILIZER.

(Citizen Contractors)

27th May, 2022

CLARIFICATION NO.1

In accordance with the “Tender for Supply, Installation and Commissioning of Automatic Voltage Stabilizer.” KenGen hereby issues Clarification No.1;

NO	ISSUE RAISED BY BIDDER	KENGEN RESPONSE
1.	Are we reusing existing cabling from the mains to the AVS and manual bypass?	No we are Not, The existing AVS is of a smaller rating than the new AVS hence the existing cable is underrated for a 500KVA AVS. The bidder shall supply new cabling from the Mains to the AVS and Manual bypass
2.	Are we reusing the busbar (Manual Bypass)?	No the bidder Must supply a New Bypass of the Correct Current Rating
3.	What is the desired length of the earthing cable?	50 meters
4.	Some bidders felt that the 500mm cable might be thick for 500Kva?	The 500mm has been correctly sized to handle Loads downstream and is the correct size

ACKNOWLEDGEMENT OF CLARIFICATION No.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date