



# KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000010122

KGN-GDD-060-2022

**TENDER FOR DESIGN, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF  
OLKARIA II AIR CONDITIONING PLANT.**

**(Citizen Contractors)**

**Date: 9<sup>th</sup> June 2022**

## **CLARIFICATION NO.1**

In accordance with the **Tender for Design, Supply, Installation, Testing, and Commissioning of Olkaria II Air Conditioning Plant** KenGen hereby issues **Clarification No.1**

No	CLARIFICATION SOUGHT	KENGEN RESPONSE
1	For the Air Handling unit, there are cooling coil and filter stage which can determine the total cooling required. Kindly and urgently provide us with ESP – External Static Pressure	Since we are not designing a new duct system, what is important is the fan capacity of the AHU. In that regard your supply fan for the AHU should be able to deliver at least 23 meters cubic of air per hour

## **ACKNOWLEDGEMENT OF CLARIFICATION No. 1**

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification has been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....