



KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000010114

KGN-GDD-065-2022

TENDER FOR SUPPLY OF CENTRIFUGAL OIL SEPARATOR VACUUM DEHYDRATOR AND LASER ALIGNMENT SYSTEM FOR WELLHEAD POWER PLANTS.

(Reserved for PLWD Enterprises).

CLARIFICATION No. 1

Date: 6th June 2022

In accordance with the **Tender for Supply of Centrifugal Oil Separator Vacuum Dehydrator and Laser Alignment System for Wellhead Power Plants**, KenGen hereby issues Clarification No. 1

No.	BIDDERS CLARIFICATION	KENGEN'S RESPONSE
1	Do you require a stationery or mobile unit	✓ The unit will be used and moved between different power plants. The unit should be compact and be able to perform as per specifications. Kindly take note of weight and dimension limitations as outlined in the technical requirements. The unit need not be mounted on trolley wheels.
2	What is the type of oil used	✓ Turbine lubrication oil
3	Kindly clarify the monitoring sensors required	✓ Temperature sensor for the heater ✓ Clogging indication system ✓ Electronic sensor that has the capacity to monitor solid particle contamination in the oil ✓ Electronic sensor that has the capacity to monitor the water content of the oil continuously, and provide a signal for controlling the unit
4	Where will the vacuum dehydrator be used.	✓ In Olkaria, to condition turbine bearings lubrication oil

ACKNOWLEDGEMENT OF CLARIFICATION No.1

We, the undersigned hereby certify that the Clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date