



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-GDD-219-2021

RFx: 5000008716

TENDER FOR SUPPLY OF PROTECTION RELAYS FOR OLKARIA POWER PLANTS.

(Citizen Contractors)

CLARIFICATION No. 1

Date: 10th December 2021

In accordance with the **Tender for Supply of Protection Relays for Olkaria Power Plants.** , KenGen issues a clarification 1 as follows:

CLARIFICATION NO. 1

No.	BIDDERS CLARIFICATION	KENGEN'S RESPONSE
1.	We have noted the subject tender calls for a particular brand, please advice if an equivalent is acceptable.	The items in the Tender specifications are expected to be direct replacements of existing protection relays. As such the models supplied should fit into existing schemes with zero modifications to facilitate minimal generation interruptions.
2	"The onsite hands-on training on the SIEMENS relay maintenance shall be conducted by certified SIEMENS Expert FOR 10 engineers and certificates should be issued to participants" can an equivalent person from a different brand be acceptable	There are existing gaps in the technical capacity within the maintenance team regarding SIEMENS relays. A certified Siemens expert hands-on training is expected to enhance the teams' competencies.

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that clarification is an integral part of the document and the alternations set out in the clarification have been incorporated in the tender proposal.

Tenderer.....

Signed.....

Dated