



KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000010122

KGN-GDD-060-2022

TENDER FOR DESIGN, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF OLKARIA II AIR CONDITIONING PLANT.

(Citizen Contractors)

Date: 13th June 2022

CLARIFICATION NO.2

In accordance with the **Tender for Design, Supply, Installation, Testing, and Commissioning of Olkaria II Air Conditioning Plant** KenGen hereby issues **Clarification No.2**

No	CLARIFICATION SOUGHT	KENGEN RESPONSE
1	In Part 2 of the tender document, Section V, Technical Specifications, Clause 2.14, it is stated that Refrigerant shall be R32 (refer to page 68 and 69), please clarify	Refrigerant requirement is R32 or R410A is Acceptable.

ACKNOWLEDGEMENT OF CLARIFICATION No. 2

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification has been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....