



KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000010027

KGN-GDD-063-2022

TENDER FOR SUPPLY OF COOLING TOWER SPARES FOR EBURRU POWER STATION.

(Citizen Contractors)

6th June, 2022

CLARIFICATION NO.2

In accordance with the “Tender for Supply of Cooling Tower Spares for Eburru Power Station.” KenGen hereby issues **Clarification No.2**;

No.	BIDDERS CLARIFICATION	KENGEN'S RESPONSE
1	<p>Provide Full model No. for Item No.3- Gear Reducer, AMARILLO.</p> <p>In reference to the subject tender please clarify on below,</p> <ol style="list-style-type: none">1. Provide the full model number for item No. 3 – Gear releser, Amarillo2. Provide the manufacturer and Model No. for item No. 4 - Complete Cooling Tower Fan Hub	<ul style="list-style-type: none">✓ AMARILLO RIGHT ANGLE FAN DRIVE.✓ OEM is AMARILLO GEAR COMPANY✓ Model No. 175, Gear ratio 7.5, Single reduction.✓ Rotation CW-CW.✓ The gear reducer is defaced, and the serial number cannot be displayed because of geothermal corrosion.✓ Geothermal environment is very harsh and corrosive.✓ Please use the gear reducer model No.175.
2	<p>We hereby request for extension of the above-named tender closing date to enable us to get all required documents from manufacturers.</p>	<ul style="list-style-type: none">✓ The spares are urgently required for the Eburru Power Plant Operation and maintenance and any further delays will jeopardise our operations.✓ We do not support for the extension of the tender period.

ACKNOWLEDGEMENT OF CLARIFICATION No.2

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date