



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-GDD-219-2021

RFx: 5000008716

TENDER FOR SUPPLY OF PROTECTION RELAYS FOR OLKARIA POWER PLANTS.

(Citizen Contractors)

CLARIFICATION No. 2

Date: 10th January 2022

In accordance with the **Tender for Supply of Protection Relays for Olkaria Power Plants.** , KenGen issues a clarification 2 as follows:

CLARIFICATION NO. 1

No.	BIDDERS CLARIFICATION	KENGEN'S RESPONSE
1.	According to the technical specifications MLFB: 7UM62215-5EB01-OAAO/FF is wrong and not compatible with what manufactures (Siemens) are providing. They are suggesting the MLFB to be either 7UM6215-5EB01-OAAO/FF or 7UM6225-5EB01-OAAO/FF. Kindly advise. SIEMENS also says the Specification shows communication Protocols and yet The MLFB used has NO communication included. Furthermore, the Communication Port C and D is in the spec but not in the MLFB. Do you need two analogue outputs? Do you need the RTD Unit?	The relay MLFB : 7UM6215-5EB01-OAAO/FF kindly include the communication protocols, analogue outputs and the RTD units as specified

ACKNOWLEDGEMENT OF CLARIFICATION NO. 2

We, the undersigned hereby certify that clarification is an integral part of the document and the alternations set out in the clarification have been incorporated in the tender proposal.

Tenderer.....

Signed.....

Dated