



# KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000009883

KGN-GDD-057-2022

## TENDER FOR SUPPLY OF INSTRUMENT SPARES FOR WELLHEAD POWER PLANTS

(Citizen Contractors)

31<sup>st</sup> May, 2022

### CLARIFICATION NO.3

In accordance with the “Tender for Supply of Instrument Spares for Wellhead Power Plants” KenGen hereby issues **Clarification No.3**;

NO	ISSUE RAISED BY BIDDER	KENGEN RESPONSE
1.	<p><b>SCHEDULE B: CONTROL VALVE SPARES</b></p> <p><b>Item 1 and 11</b></p> <p>Please could you assist us, we require the actuator details in order to add the correct brackets as per your request.</p>	<p>Kindly provide the intelligent valve controllers item 1 and 11 as per the model numbers provided in the tender.</p> <p>Item 1: <b>Type:</b> ND9106HNT/156 Item 11: <b>Type:</b> SG9237HNT/156</p>
2.	<p>No.10. Temperature gauge Manufacturer - REOTEMP instruments.</p> <p>Model no: MM0401C43SF</p> <p>The manufacturer is saying the model number does not match with the description you gave for this items and they asked should they quote per model number or description.</p>	<p>Use the model number.: MM0401C43SF</p>
3.	<p>We have been notified by one of our suppliers of spares that the required model/spares (item 7 of Schedule A) have been discontinued from production and has since been replaced by a new model "1900/65A-01-01-01-00-01. Kindly clarify if the new model that the manufacturer is proposing is acceptable to you.</p>	<p>Kindly supply a direct replacement of the 1900/27 as recommended by the manufacturer and as the tender specifications.</p> <p><b>Power supply 85-264 VAC 47-440Hz 110-370 VDC ~ 60mA Max Alert relays and danger relays with Relay rating: 28VDC 6A or 300VAC 6A Should have transducer inputs connections. Should have 4-20 mA output loop outputs. Buffered velocity</b></p>

		<p><b>Proper mounting and connectors should be provided</b></p> <p>Kindly note we are not replacing the sensors on site.</p>
--	--	--

**ACKNOWLEDGEMENT OF CLARIFICATION No.3**

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date .....