



KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-BDD-003-2024

TENDER FOR INSTALLATION AND UPGRADING OF SOLAR AUTOMATIC WEATHER STATIONS

(OPEN NATIONAL)

RFx: 5000014838

Date: 5th April, 2024

CLARIFICATION NO. 1:

In accordance with the ‘**Tender for Installation and Upgrading of Solar Automatic Weather Stations**’, KenGen hereby issues **Clarification No. 1** as follows.

No.	Bidder’s Request for Clarification	KenGen’s Response
1	Is the existing rain gauge a tipping bucket, which has a switch output?	The existing rain gauge is a Vaisala Rain Gauge RG13 (<i>refer to the user manual</i>) The rain gauge uses a pulse-based tipping bucket mechanism to produce a contact closure every time it receives a predetermined quantity of rainfall.

BIDDER’S ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned, hereby certify that the Clarification is an integral part of the document and the alterations set out in Clarification have been incorporated in our tender document.

Signed

Tenderer

Date