



**KENYA ELECTRICITY GENERATING COMPANY PLC**

**KGN-HYD(tana)-05-2023  
TENDER FOR DESIGN, SUPPLY, INSTALLATION, TESTING AND  
COMMISSIONING OF BUTTERFLY VALVES AT SAGANA POWER STATION  
(Open International)  
RFx 5000012045**

**6<sup>th</sup> March, 2023**

**CLARIFICATION NO. 1:**

In accordance with the tender for ‘**Design, Supply, Installation, Testing and Commissioning of Butterfly Valves at Sagana Power Station**, KenGen hereby issues **Clarification No. 1** as follows;

<b>NO.</b>	<b>CLARIFICATION REQUESTED</b>	<b>KENGEN RESPONSE</b>
1	Please share the technical Specification related to material of construction of the required valves	Bidders shall refer to the Tender on the applicable standards and codes as stated in “SECTION V-TECHNICAL SPECIFICATIONS & SCHEDULE OF REQUIREMENTS item 5.0. Standards and Codes”.
2	The valves required are hydraulically operated. Please confirm if you require a counter balancing mechanism for the valves	Yes. As specified under “DETAILED TECHNICAL SPECIFICATIONS, item 2.3 of the tender document.
3	Please share the existing valve drawings, datasheets, and site pictures	KenGen has no drawings available due to age of plant(1956) and also the new valve to be installed bears no similarity to the existing valve
4	Please advise whether we need to also service and repair the existing valve after decommissioning	This is not a scope in the tender.
5	We kindly request for 2 weeks extension to allow us participate	Extension granted as per <b>Addendum 1</b>

**BIDDER’S ACKNOWLEDGEMENT OF CLARIFICATION NO.1**

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in Addendum have been incorporated in our tender document.

**Signed .....**

**Tenderer** .....

**Date** .....