



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-HYD-021-2024

RFx: 5000014980

TENDER FOR REHABILITATION OF FIRE HYDRANT SYSTEMS IN EASTERN HYDRO POWER STATIONS AND STAFF CAMPS (RE-TENDER)

(YOUTH ENTERPRISES ONLY)

Date: 25th April 2024

CLARIFICATION NO.1:

In accordance with the **TENDER FOR REHABILITATION OF FIRE HYDRANT SYSTEMS IN EASTERN HYDRO POWER STATIONS AND STAFF CAMPS**. KenGen hereby issues Clarification No.1

NO	CLARIFICATION SOUGHT	KENGEN'S RESPONSE
1	This is to request for an extension of the submission deadline by seven (7) days as we are experiencing delays from some of the manufacturers.	The tender closing date has been extended to 2nd of May 2024 at 10.00 a.m.as per addendum No. 2 on our website
2	According to the flow rate given for the Motor driven pump which is 600-1000lpm and a head of 80-100m, the motor that can match those specs is a mult-stage pump driven by a 20-50kw motor, which is not what you have specified, so kindly revise those specs and all other that will be affected by that change.	The specified motor assembly has been proven to successfully drive the centrifugal single-stage pump provided in the tender document The tender closing date has been extended to 2nd of May 2024 at 10.00 a.m.as per addendum No. 2 on our website

	also consider revising the closing date for us to effect the changes	
3	Kindly clarify the cross-sectional area of the external 200m long 3phase cable on schedule 4 pump house skid pump & reticulation, item no. 9 Electricals	It is armoured 3-core cable of cross-sectional area 6mm ²
4	I would like to request for extension of the below tender due to lots of changes from the site visit.	Because of some changes after the site visit, the tender closing date has been extended to 2nd of May 2024 at 10.00 a.m.as per addendum No. 2 on our website

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification has been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....