



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000011871

KGN-GDD-016-2023

TENDER FOR DESIGN, MANUFACTURE, DELIVERY, SUPERVISION OF ASSEMBLY, TESTING AND COMMISSIONING OF 70MVA, 11/220KV, ONAN/ONAF STEP UP TRANSFORMER FOR OLKARIA, WELLHEAD 914 SUBSTATION.

(Open International)

Dated: 17th February, 2023

Clarification No.1.

In accordance with the Tender for Design, Manufacture, Delivery, Supervision of Assembly, Testing and Commissioning of 70MVA, 11/220KV, ONAN/ONAF Step Up Transformer for Olkaria, wellhead 914 Substation, KenGen issues a Clarification No. 1 as follows:

No.	BIDDERS CLARIFICATION	KenGen's RESPONSE
1	Type Test Report: Are we allowed to submit a higher rating of more than 70MVA Power Transformer?	This is ok, provided the bidder is able to demonstrate that a 70MVA transformer as will be supplied is also covered by such tests.
2	Transformer Monitoring System: No technical specifications, Is there information including on both sub clauses in the GTP 28.1 and 28.2	There is no transformer monitoring system in the scope of supply. sections 28, 28.1, 28.2 is Expunged from the Technical Schedule, refer to Addendum No.2

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....