



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000014678

KGN-GDD-032-2024

TENDER FOR SUPPLY, INSTALLATION & COMMISSIONING OF TRUCK WEIGHBRIDGE.

(Women Enterprises)

Dated: **4th March, 2024**

Clarification No.1.

In accordance with the **Tender for Supply, Installation & Commissioning of a Truck Weigh Bridge**, KenGen issues **Clarification No.1** as follows:

	BIDDERS CLARIFICATION	KenGen's RESPONSE
1.	<ol style="list-style-type: none">1. Kindly give us a detailed dimension of the weighbridge control room (length X width X height) with six (6) technical staff with one (1) weighbridge operator to be within the office.2. kindly also let us know the number of office desk & chairs required to be supplied.3. Number of doors & windows required for above office.4. Type of materials require to build above office. Does it require a washroom?	<ol style="list-style-type: none">1.The office shall be 12000x2500x2600mm (40'x8'x8'6") containerized unit divided into three (3) equal offices. Each office has two (2) L-shaped office desks (L×W×H), 1400×1200×725mm, office desks and two office chairs. All offices shall have a 1200BTU air conditioning unit. The roofing and walling shall be suited with proper insulation. Flooring shall be level, skid proof with no gaps2.Bidders shall provide detailed drawings for the office detailing dimensions and layout. Power sockets and an adequate LAN port shall be provided. Electrical ready to connect 230-250V, 50HZ power supply complete with adequate twin sockets, earthing, switches, and lighting strips to meet the power requirements of each office.3.The Weighbridge control room shall be 6000x2500x2600mm (20'x8'x8'6"). The container shall be divided into two (2) with one side weighbridge operation and control and other side filling office. The roofing and walling shall be suited with proper insulation and fitted with 1200BTU air conditioning unit. Power sockets and an adequate LAN port shall be provided. Electrical ready to connect 230-250V, 50HZ power supply complete with adequate twin sockets, earthing, switches, and lighting strips to meet the power requirements of each office. Bidder shall provide detailed drawing.4.Total number of office desks- Ten (5L and 5R) office desks 1400×1200×725mm fitted with lockable drawers and Ten (10) high back adjustable office chairs.5.Each office shall have one door Double door, dimension, L×W, 2500 x 1000mm and 50mm thickness. One 1000x1000mm double glazed

Aluminum/PVC slide window with steel bars. All doors shall be equipped with non-slip steps. No washroom required.

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....