



**KENYA ELECTRICITY GENERATING COMPANY PLC**

**RFx: 5000016588**

**TENDER No. KGN-OLK-006-2025**

**TENDER FOR SUPPLY OF CONTROL SPARES FOR THE WELLHEAD POWER PLANTS**

**(Women Enterprises)**

**Dated: 19<sup>th</sup> March, 2025**

**Clarification No.1.**

In accordance with the **Tender for Supply of Control Spares for Wellhead Power Plants**, KenGen issues a **Clarification No.1** as follows:

No	BIDDERS CLARIFICATION	KenGen's RESPONSE
1	With regards to the above tender, 'Schedule 2' items no. 13 & 14 from Janitza have been discontinued according to the manufacturer. They have given successor models which can be used instead of the requested products. Do we proceed to bid with the successor models?	Provide direct successors, provided they fully meet the technical specifications, performance requirements and all the communication interfaces (e.g RS485, RS 232 and Profibus DP ) as outlined in the tender.

**SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION No.1**

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....