



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000014682

KGN-OLK-012-2024

TENDER FOR SUPPLY OF TURBINE ROTOR AND ACCESSORIES FOR EBURRU POWER STATION.

(Citizen Contractors)

Dated: 6th March, 2024

Clarification No.1.

In accordance with the **Tender for Supply of Turbine Rotor and Accessories for Eburru Power Station**, KenGen issues a **Clarification No. 1** as follows:

	BIDDERS CLARIFICATION	KenGen's RESPONSE
1	Factory Acceptance test & Inspection (FAT& I)	<ul style="list-style-type: none">➤ The FAT & I will be conducted during the progress of the manufacture of parts and almost towards the tail end for the following reasons.<ul style="list-style-type: none">i. Material testing and inspectionii. Physical inspection and verification of the spare's quantities for dimensions, geometrical shapes, and sizes.iii. The Supplier/tenderer to organize by liaising with the manufacturer (OEM) of when parts/spares are ready for the FAT to be carried out.iv. The costs of FAT for air travels & accommodation to be incurred by KenGen Plc.
2	Design review for engineering drawings designs	<ul style="list-style-type: none">➤ There will be a discussion for the design review of the technical engineering drawings for the turbine rotor and diaphragm designs & spares (if supply of components (parts) and spares is not from the OEM).➤ This process will inform the start of the manufacturing process.

		➤ The parts & spares will then be delivered for fitment and commissioning of the Eburru Turbine hence the power plant.
--	--	--

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION No.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....