



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000014992

KGN-OLK-028-2024

TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF INDUSTRIAL BATTERY BANKS FOR OLKARIA II & IAU POWER STATIONS.

(Reserved for Women Enterprise)

Dated: 16th April, 2024

Clarification No.1.

In accordance with the **Tender for Supply, Installation, Testing and Commissioning of Industrial Battery Banks for Olkaria II & IAU Power Stations**, KenGen issues **Clarification No.1** as follows:

	BIDDERS CLARIFICATION	KenGen's RESPONSE
1.	<p>Kindly clarify the below as indicated in the technical Specifications' for SCHEDULE A – OLKARIA II 240Vac UPS SYSTEM BATTERY BANK</p> <p>1.The bank consists of a total of 38 cells each rated 6Volts (nominal), 200Ah. One bank of 38 batteries will be connected in series to give a 200Ah, 240Vdc bank. An additional three (3) batteries shall be delivered as spares making a total of 42.</p> <p>The total for 38+3=41 but you have indicated 42?</p>	<p>An additional Four (4) batteries shall be delivered as spares making a total of 42.</p>

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....