



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000015005

KGN-OLK-030-2024

TENDER FOR DESIGN, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AN ONLINE BATTERY MONITORING SYSTEM FOR OLKARIA 1AU POWER STATION.

(Citizen Contractors)

Dated: 5th April, 2024

Clarification No.1.

In accordance with the **Tender for Design, Supply, Installation, Testing and Commissioning of An Online Battery Monitoring System for Olkaria 1AU Power Station**, KenGen issues **Clarification No.1** as follows:

	BIDDERS CLARIFICATION	KenGen's RESPONSE
1.	What is the battery voltage and Ah?	The battery ratings are 2V, 1500Ahr as indicated in Tender Document under Introduction in the Technical Specifications (Page 62)
2.	How many batteries per bank?	No of batteries ratings are one hundred and eight (108) as indicated in Tender Document under Introduction in the Technical Specifications (Page 62)
3.	How many banks per UPS	There will be two (2) banks comprising of 54cells each as indicated in Tender Document under Introduction in the Technical Specifications (Page 62)

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....