



**KENYA ELECTRICITY GENERATING COMPANY PLC**

**RFx: 5000016305**

**TENDER No. KGN-GDD-011-2025**

**TENDER FOR SUPPLY OF GEOTHERMAL WELLHEAD EQUIPMENT.  
(Expanding Gate Valves & Adaptor Flanges)**

*(Open International)*

Dated: 17<sup>th</sup> February, 2024

**Clarification No.2.**

In accordance with the **Tender for Supply of Geothermal Wellhead Equipment**, KenGen issues a **Clarification No. 2** as follows:

	<b>BIDDERS CLARIFICATION</b>	<b>KenGen's RESPONSE</b>
1.	<p>We would like to seek clarification regarding the specifications for <b>Item No. 6</b> as outlined in Section V, Schedule of Requirements, Page 58 of the tender document.</p> <p>Our supplier has advised that the thread pitch for 7/8" should be 9UNC instead of 8UNC, contrary to the specifications provided. They insist that 9UNC is the correct thread pitch for this size. Could you kindly confirm whether the specified 8UNC is indeed the required standard, or if 9UNC would be acceptable?</p>	<p>The studs shall be <b>8UN- 7/8"</b></p>

**SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION No.2**

We, the undersigned hereby certify that the Clarification No.2 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....