



**KENYA ELECTRICITY GENERATING COMPANY PLC**

**RFx: 5000016522**

**TENDER No. KGN-GDD-014-2025**

**TENDER FOR SUPPLY OF STEAMFIELD MONITORING EQUIPMENT AND INSTRUMENTS FOR STEAMFIELD MANAGEMENT.**

*(Citizen Contractors)*

Dated: 14<sup>th</sup> March, 2025

**Clarification No.2.**

In accordance with the **Tender for Supply of Steamfield Monitoring Equipment and Instruments for Steamfield Management.**, KenGen issues **Clarification No.2** as follows:

No	BIDDERS CLARIFICATION	KenGen's RESPONSE
1	Due to the intensity of the scope of work and the time constraints, we are kindly requesting for an extension of 2 weeks	Refer to <b>Addendum No.2</b> uploaded on our website addressing extension request.
2	<p>1 INCH HORIZONTAL INVERTED BUCKET STEAM TRAPS Capacity: 9,072 kg/hr</p> <p>1 INCH VERTICAL INVERTED BUCKET STEAM TRAPS Capacity: 9,072 kg/hr</p> <p>MECHANICAL FREE FLOAT 1 INCH STEAM TRAP Capacity: 15,000 kg/hr</p> <p>Further to the above listed STEAM TRAPS, kindly confirm capacity required per hour since the 9,072 kg/hr and 15,000 kg/hr cannot be achieved with a 1 inch steam trap.</p>	<p>Required capacities are as stated <b>Addendum No.1</b> uploaded on our website.</p> <p><b>MECHANICAL FREE FLOAT 2 INCH STEAM TRAP</b></p> <p>SIZE: 2 inch or DN 50</p> <p>CONNECTION: 2-inch Socket Weld</p> <p><b>2 INCH CLASS 600 Y STRAINER, SOCKET WELD END</b></p> <p>SIZE: 2 inch or DN50</p> <p>PIPE CONNECTION: 2-inch welded</p>

**SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION No.2**

We, the undersigned hereby certify that the Clarification No.2 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....