



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-GDD-030-2025

RFx: 5000016652

**TENDER FOR SUPPLY OF STEAMFIELD MAINTENANCE SPARES FOR
STEAMFIELD MANAGEMENT**

(WOMEN ENTERPRISES)

Date: 2nd April 2025

Clarification No. 2

In accordance with the tender for “**Tender for Supply of Steamfield Maintenance Spares for Steamfield Management**”, KenGen hereby issues **Clarification No. 2** as follows:

	BIDDERS CLARIFICATION	KenGen’s RESPONSE
1.	For the flange please tell me the flange type and the material grade.	Refer to the specified standard in the tender
2.	For all Spiral wound gasket, please tell me the material grade of the outer ring, filling and the inner ring. Are they for the RF flange or FF flange?	Kindly refer to clarification 1 uploaded on our website for the gasket details. Flange is RF
3.	For all Stud bolt with nut, please confirm the material grade is A193 B7/A194 2H?	grade is A193 B7/A194 2H is okay

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION No.2

We, the undersigned hereby certify that the Clarification No.2 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....