



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000016305

TENDER No. KGN-GDD-011-2025

**TENDER FOR SUPPLY OF GEOTHERMAL WELLHEAD EQUIPMENT.
(Expanding Gate Valves & Adaptor Flanges)**

(Open International)

Dated: 21st February, 2024

Clarification No.3.

In accordance with the **Tender for Supply of Geothermal Wellhead Equipment**, KenGen issues a **Clarification No. 3** as follows:

	BIDDERS CLARIFICATION	KenGen's RESPONSE
1.	We appreciate your response confirming that the required thread pitch for the 7/8" stud bolt should be 8UN. However, after further consultation with multiple suppliers and reviewing industry standards, we have encountered consistent feedback that the standard thread pitch for a 7/8" stud bolt is typically 9UNC rather than 8UN. Given this discrepancy, could you kindly confirm whether the specified 8UN requirement is based on a specific project need or an industry reference we may have overlooked? This clarification will help us ensure that the supplied materials fully align with the intended application. We appreciate your guidance on this matter.	The studs shall be 8UN- 7/8" . The stud bolts are used on the geothermal wellhead equipment.

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION No.3

We, the undersigned hereby certify that the Clarification No.3 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....