



**KENYA ELECTRICITY GENERATING COMPANY PLC**

**RFx: 5000016522**

**TENDER No. KGN-GDD-014-2025**

**TENDER FOR SUPPLY OF STEAMFIELD MONITORING EQUIPMENT AND INSTRUMENTS  
FOR STEAMFIELD MANAGEMENT.**

*(Citizen Contractors)*

Dated: 17<sup>th</sup> March, 2025

**Clarification No.3.**

In accordance with the **Tender for Supply of Steamfield Monitoring Equipment and Instruments for Steamfield Management.**, KenGen issues **Clarification No.3** as follows:

No	BIDDERS CLARIFICATION	KenGen's RESPONSE
1	1) Capillary lengths 2) The flange size (inches) 3) The Flange Type ( ANSI of Din ) 4) The flange rating ie: 150lb or 300lb etc etc 5) And the Diaphragm material ( in most cases it will be 316 sst but if there is any acidic properties in the measured fluid/gas it could be an exotic steel like hasteloy-c etc) 6) Looking at the Temperature spec we would have to use hight temp fill fluid	Flange size 2" as specified in tender, ASTM B16.5 A182Gr 316/316L, class 150lbs, Diaphragm SS 316L, capillary length >30 ft

**SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION No.3**

We, the undersigned hereby certify that the Clarification No.3 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....