

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000014833

KGN-OLK-019-2024

TENDER FOR SUPPLY OF VENT STATION VALVES FOR OLKARIA II POWER STATION.

(Women Enterprises)

Dated: 12th April, 2024

Clarification No.5.

In accordance with the **Tender for Supply of Vent Station Valves for Olkaria II Power Station**, KenGen issues **Clarification No.5** as follows:

	BIDDERS CLARIFICATION	KenGen's RESPONSE
1.	i) FAT	
		Basing on the employer's vast experience in valve
	(i) Our Manufacturer has informed us that	and actuator operations and maintenance, a
	considering the scope of this tender, a virtual	virtual FAT will not be effective and is therefore
	FAT would be a better option (cost effective)	not acceptable. Bidders are requested to adhere to
	for KENGEN.	the tender requirement.
2.	(ii) Training of KENGEN Staff	Basing on the training needs KenGen has
		determined a 10 Day training to be sufficient to
	(ii) After consultation with our	adequately cover the minimum scope as required
	Manufacturer, a 10 Day training session at	by the tender. However, the bidder may provide a
	the manufacturer's site is deemed to be	training proposal attached to the bid highlighting
	excessive and could be easily covered during	the proposed number of days the training will
	the FAT, however, not in the way presented in	take and the topics to be covered.
	the ITT. Our manufacture is not a training	•
	school and cannot provide certification.	Please note that the training requirement on
	Kindly advise.	minimum subjects, Certified Valve and Actuator
		trainers and issuing of certificates to trainees as
		specified in the tender, MUST be adhered to for
		the bid to be considered as responsive
		the bia to be considered as responsive

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.5

We, the undersigned hereby certify that the Cla	irification No.5 is a	an integral j	part of the d	locument and
the alterations set out in Clarification has been i	incorporated in the	e Tender Pr	oposal.	

Signed	
Tenderer	
Date	