



TENDER NO. KGN-HYD-052-2021:

TENDER FOR DESIGN, MANUFACTURE, DELIVERY, SUPERVISION OF ASSEMBLY, TESTING AND COMMISSIONING OF 40MVA, 11/132KV, ONAN/ONAF GENERATOR STEP UP TRANSFORMER FOR KAMBURU POWER STATION

9th December, 2021

In accordance with the tender for “Tender for Design, Manufacture, Delivery, Supervision of Assembly, Testing and Commissioning Of 40MVA, 11/132KV, ONAN/ONAF Generator Step Up Transformer for Kamburu Power Station” KenGen hereby issues;

Clarification No.1

NO.	CLARIFICATION REQUESTED	RESPONSE TO THE BIDDER
1.	<p>We refer to your tender for 40MVA Transformer. Tender asks for capitalization for losses. We request you to kindly give us capitalization formula as per your tender requirement clause no 18.9, enclosed herewith for your ready reference.</p> <p>Normally for domestic industrial as well as Utility use capitalization is decided as per CBIP manual with present tariff rates.</p>	<p>The expected life of the transformer is 30 years.</p> <p>The bidder is expected to calculate the amortized cost of the transformer losses (both No-load and Full-load losses), taking into account the life span of the transformer.</p> <p>The bidder should consult the transformer manufacturer for the figures.</p>

ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the Clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....