



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx 5000008700

KGN-GDD-213-2021

TENDER FOR SUPPLY OF BATTERIES FOR OLKARIA 1 AU POWER PLANTS

CLARIFICATION No. 2

Date: 11th January 2022

In accordance with the Tender for Supply of Batteries for Olkaria 1 AU Power Plants, KenGen issues a clarification 2 as follows:

No.	BIDDERS CLARIFICATION	KENGEN'S RESPONSE
1.	On price schedule item 1 you have requested for 2V, 1440AH VRLA Valve Batteries. Can we bid for 2V, 1500AH instead of 2V, 1440AH to ensure the consistency of the batteries.	All the cells can be at 2V, 1500AHr with all other specifications and requirements maintained

ACKNOWLEDGEMENT OF CLARIFICATION NO. 2

We, the undersigned hereby certify that clarification is an integral part of the document and the alternations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....