



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-TANA-002-2024



RFx: 5000014597

**TENDERS FOR SUPPLY OF LIFTING TOOLS FOR MESCO POWER STATION.
(RESERVED FOR WOMEN)**

Date: 22nd February, 2024

CLARIFICATION NO. 3:

In accordance with the 'Tenders for Supply of Lifting Tools for Mesco Power Station', KenGen hereby issues **Clarification No. 3** as follows.

No.	Bidder's Request for Clarification	KenGen's Response		
1	<p>lastly, for items 8 and 9 i.e., the 12T ratchet buckles, please confirm if:</p> <ol style="list-style-type: none"> 1. The tonnage refers to the Breaking strength or lashing capacity 2. The type of hook required at the belt end e.g., Double J hook, claw/triangle/snap/flat hook 	8	<p>Ratchet buckles 12 ton</p>  <p>Zinc plated steel 1"x 4 7/16"</p>	<ol style="list-style-type: none"> 1. The tonnage should be the breaking strength and not the lashing capacity 2. The preferred hook type is double J hook with safety latch
		9	<p>Ratchet buckles 12 ton</p>  <p>Stainless steel 1"x 4 7/16"</p>	<ol style="list-style-type: none"> 1. The tonnage should be the breaking strength and not the lashing capacity 2. The preferred hook type is double J hook without safety latch

BIDDER'S ACKNOWLEDGEMENT OF CLARIFICATION NO. 3

We, the undersigned, hereby certify that the Clarification is an integral part of the document and the alterations set out in Clarification have been incorporated in our tender document.

Signed

Tenderer

Date