



# KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000008719

## TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF FIRE HYDRANT SYSTEM FOR OLKARIA LAKEVIEW HOUSING ESTATE.

TENDER No. KGN-GDD-212-2021

(Reserved for PLWD)

Date: 14<sup>th</sup> January, 2022

### CLARIFICATION No. 1

In accordance with the Tender for Supply, Installation, Testing and Commissioning of Fire Hydrant System for Olkaria Lakeview Housing Estate, KenGen hereby issues **clarification No.1;**

NO.	BIDDER'S QUESTION	KENGEN'S RESPONSE
1	On page 65 of the tender document it's stated that "The fire station shall have a sufficient canopy and sidewall to protect the equipment there in from sunlight and ingress of water." could you please clarify on the material specification to be used for the canopy e.g. Roof type, Floor type, Wall type etc. Can you also provide the drawing of the dimensions of the canopy	We leave it to the bidder to come up with the drawings of the dimensions of the canopy because it will depend on the type of the fire station components the bidder will get in the market; some can be compact type which require smaller dimensions, others can be robust type which require bigger dimensions. Material to be used for the canopy and side wall to be galvanized corrugated sheets which will withstand the prevailing environmental conditions. The floor type to be exterior stained concrete which should slope towards the provided oil trap for draining purposes.

### ACKNOWLEDGEMENT OF CLARIFICATION No.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date .....