



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000012280

KGN-SONDU-13-2023

**TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF
AIR CONDITIONING UNITS FOR SANG'ORO POWER STATION
(YOUTH ENTERPRISES ONLY)**

Dated: 17th March, 2023

Clarification No.1.

In accordance with the **Tender for Supply, Installation, Testing & Commissioning of Air Conditioning Units for Sang'oro Power Station**, KenGen issues **Clarification No.1** as follows:

No.	CLARIFICATION SOUGHT	KENGEN'S RESPONSE
I	Confirm if there is an error in the technical specification or if there are specific reasons why R410C refrigerant has been specified, and not RC410A which is approved by EPRA.	This is an error in the technical specifications. RC410A is the preferred refrigerant. (Please refer to addendum No. 1)

ACKNOWLEDGEMENT OF CLARIFICATION No.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....