



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000014839

KGN-OLK-021-2024

TENDER FOR SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF 2.5MVA EMERGENCY DIESEL GENERATOR AND ACCESSORIES FOR OLKARIA II POWER STATION.

(Open National)

Dated: 19th March, 2024

Clarification No.1.

In accordance with the **Tender for Supply, Installation, Testing, and Commissioning Of 2.5MVA Emergency Diesel Generator and Accessories for Olkaria II Power Station**, KenGen issues a **Clarification No.1** as follows:

	BIDDERS CLARIFICATION	KenGen’s RESPONSE
1.	we are working on the above-mentioned tender and would like to clarify the voltage output/category for the proposed generator is it 415v/11kv?	The output voltage for the 2.5MVA Emergency Diesel Generator is 3.3kV.

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....