



KENYA ELECTRICITY GENERATING COMPANY PLC

RFx: 5000015000

KGN-OLK-029-2024

**TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 11kV
CIRCUIT BREAKER FOR OLKARIA II POWER STATION.**

(Citizen Contractors)

Dated: 16th April, 2024

Clarification No.1.

In accordance with the **Tender for Supply, Installation, Testing and Commissioning of 11kV Circuit Breaker for Olkaria II Power Station**, KenGen issues **Clarification No.1** as follows:

	BIDDERS CLARIFICATION	KenGen’s RESPONSE
1.	<p><u>Technical Specifications for the 11KV Circuit breaker</u> Technical Specifications for 11KV Vacuum Circuit Breaker, the stated Type is 10 VPR 32C, but through the enlightenment of our manufacturers, the vacuum circuit breaker type has upgraded from 10 VPR 32C, to 10 VPR 32D</p>	<p>The upgrade is acceptable. However, the dimensions should match the existing dimension of the 10-VPR-32C. If not, then the bidder shall be required to carry out the modifications on the existing panel at no additional costs to KenGen PLC.</p> <p>The proposed modifications and duration of the works to be carried out shall form part of the bid to be submitted for evaluation.</p> <p>Attach the brochure to clearly indicate the dimensions of the new breaker.</p>

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification No.1 is an integral part of the document and the alterations set out in Clarification has been incorporated in the Tender Proposal.

Signed.....

Tenderer.....

Date.....