



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-SONDU-001-2025

RFX: 5000016597

**TENDER FOR SUPPLY AND DELIVERY OF COOLING WATER SYSTEM GI PIPES FOR SANG'ORO POWER STATION**


**(CITIZEN CONTRACTORS)**

**Date: 28<sup>th</sup> March, 2025**

**Clarification No.2**

In accordance with the **TENDER FOR SUPPLY AND DELIVERY OF COOLING WATER SYSTEM GI PIPES FOR SANG'ORO POWER STATION**, KenGen hereby issues **Clarification No.2**

BIDDER'S CLARIFICATION	KENGEN RESPONSE										
Clarify on the length of items 1, 2, 3, and 4 since what is on description and qty columns do not add up.	<ul style="list-style-type: none"> <li>The quantity is as per the description in the document <table border="1" style="margin-left: 20px;"> <thead> <tr> <th>Item No.</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>18</td> </tr> <tr> <td>2</td> <td>10</td> </tr> <tr> <td>3</td> <td>14</td> </tr> <tr> <td>4</td> <td>10</td> </tr> </tbody> </table> </li> </ul>	Item No.	Quantity	1	18	2	10	3	14	4	10
Item No.	Quantity										
1	18										
2	10										
3	14										
4	10										
What is the length and diameter of items 7, 11, 13, 15, and 19	Kindly refer to the technical specifications on the tender document on the fitting section. On the table for the bolts specifications, refer to the 3rd column on the Dia of Bolt and <b>last 2 columns on the Length of Bolts</b>										
. which is the correct size of item 17; it is indicated 3/4 stud bolt but size is indicated as M12x140	On the table for the bolts specifications, refer to the 3rd column on the Dia of Bolt and last 2 columns on the Length of Bolts , i.e. 1/2" = M12										
Clarify on the material for item 20 and 21; is the valve body stainless steel or carbon	The technical specification for the butterfly valve as in the document is Material -Ductile Iron, SPECIFICATION - ASTM A395 Gr. 60-40-18.										
Give more technical details for items 22, 24 and 25	Refer to the technical specifications on the tender document on Section C on the specification and dimensions of the control valves										

<p>Clarify on the type of NRV needed for item 26 and if possible share pictures</p>	
<p>Clarify on item 38 whether you need a cross Tee 6"</p>	<p>Yes, item # 38 - Cross-junction " " == Cross Tee 6"</p>

**BIDDER'S ACKNOWLEDGEMENT OF CLARIFICATION NO.1**

We, the undersigned hereby certify that the **Clarification** is an integral part of the document and the alterations set out in Addendum have been incorporated in our tender document.

Signed .....

Tenderer .....

Date .....