



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-OPS-01-2023

RFx: 5000012333

TENDER FOR MACHINING AND FABRICATION OF PARTS FOR KenGen EQUIPMENT. (Framework Contract for Three (3) Years) (Open National)

Date: 19th April, 2023

Clarification No. 1

In accordance with the **Tender for Machining and Fabrication of Parts for KenGen Equipment**, KenGen issues **Clarification No. 1** as follows:

No	Bidders Request for Clarification	KenGen's Response
1.	Submission of datasheets during bidding.	It is a MANDATORY requirement to attach a brochure/catalogues/ product data sheet for each item quoted, for new parts to be supplied. For catalogue/ brochures with several item options, Bidder is required to mark out clearly the specific items they intend to supply/ have quoted for.
2.	Attachment of delivery notes of a similar value.	The bidder may attach a delivery note, signed contract or any other documentation, that will allow KenGen verify the correctness of the details therein if it will be necessary.
3.	Requirement for 3 years Audited Accounts.	Bidders will submit copies of their audited financial statements by a registered audit firm for the last one (1) year and must demonstrate the current soundness of the Bidder's financial position and its prospective long-term profitability.
4.	Site visit certificates.	All the attendance sheets for the site visits have been attached as an addendum. The bidders are requested to download and stamp on the attendance sheet where they appear and attach this to their tender proposal.

5.	Site Visit	There will be another site visit on 25 th April 2023 from 10:00am. Those who attended need not attend again.
6.	Please clarify whether dynamic balancing will be done at high speeds or at low speeds.	The balancing will be done at low speeds
7.	Some items did not have the drawings attached, and there were no estimated quantities.	Please refer to the new requirements and price lists as annexed. The drawings have also been updated on the website.

No	Bidders Request for Clarification				KenGens Response
8	Schedule I: WANJII POWER STATION	ITEM 21	WANJII MARAGUA SP ILL GATE POWER SCREW GUIDE	The dimensions provided are insufficient. The thickness is missing; the diameter of the bore is missing as is the depth.	Drawing No. WAN-18-2023 attached has been updated with the required information.
9	Schedule I: WANJII POWER STATION	ITEM 25	WANJII WINCH WHEEL	The dimensions of the hub are missing. The outside diameter is 435mm. when you Subtract 50mm as shown, it does not add up to the other diameter shown i.e. 387mm. The thickness of the supports of the hub arc missing	Drawing No. WAN-22-2023 attached has been updated with the required information.
10	Schedule IV: TANA: POWER STATION .	ITEM 6 and 7	MARAGUA TURBINE SHAFT SLEEVE AND MERILLA TURBINE SHAFT SLEEVE	The grade of Stainless Steel is missing	The material is Stainless steel 316 coated with tungsten carbide in the portions shown in the attached drawing no TAN-05-2023

SUPPLIER ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in clarification has been incorporated in the tender document.

Signed.....

Tenderer.....

Date.....