

### KENYA ELECTRICITY GENERATING COMPANY PLC

#### KGN~HYD~034~2024

#### RFx: 5000015548

### TENDER FOR A SUBMERSIBLE DEWATERING PUMP FOR KAMBURU POWER STATION.

# (Reserved for Youth Enterprises)

20<sup>th</sup> June, 2024

## **CLARIFICATION NO.1**

In accordance with the "*Tender for a Submersible Dewatering Pump for Kamburu Power Station,*" KenGen hereby issues, Clarification No.1

No.	Bidder's Clarification	KenGen's Response
1	In the bid documents in page 59 it states that the pump shall be of similar design to the existing one you have and is to be replaced, thereby enabling it to be easily assembled and mounted in the existing stool arrangement for existing pump as per the attached sketches. 1. There is no any attached sketches. Hence requesting for pictures for the existing pump please.	Guide Balls often Invention Balls often Invention Pre-
2	Could you kindly share a photo of the nameplate or tag plate of the existing pump to assist us in pump selection.	Name Plate

3	Manufactures comment "The information you have provided doesn't make sense. You ask for pumps to deliver 190ltr/sec at 24mtr total head. Is this requirement for each pump or with 2 or 3 pumps running simultaneously as the existing Flygt pumps cannot provide this flow individually" yet the price schedule is for 1 piece. On the Flygt 3300 information attached please indicate which impeller number you currently have installed?	The pump can singly deliver over 190Lrs/Sec at a head of 24mtrs
4	Is it possible for you to provide a Duty point for this application. The Flyght C3300 has 2 types of hydraulics that can accompany the pump, Namely MT and HT wet end. Please can you confirm what the duty requirements are on site. We need to know the head and flow requirements to make a suitable replacement pump selection.	The existing pump is CP3300.181whose performance curves are publicly available

# ACKNOWLEDGEMENT OF CLARIFICATION-NO-1.

We, the undersigned hereby certify that the Clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....