

KENYA ELECTRICITY GENERATING COMPANY PLC

KGN~SONDU~003~2024

RFx NO: 5000014606

TENDER FOR SUPPLY OF LIFTING EQUIPMENTS FOR SONDU AND SANG'ORO POWER STATION [WOMEN ENTERPRISES ONLY]

Date: 21st February, 2024

Clarification No.2

In accordance with the **Tender for Supply of Lifting Equipment for Sondu and Sang'oro Power Station**, KenGen hereby issues **Clarification No.2.** as follows.

1	Schedule of Requirements Page 63-64, Tender	the safety factor of webbing slings is 4 times the
	Document.	rated tonnage capacity.
	SAFETY FACTOR OF WEBBING SLING LIFTING	
	EQUIPMENT	
	Kindly provide the safety factor of the webbing	
	slings requested.	

BIDDER'S ACKNOWLEDGEMENT OF CLARIFICATION NO.2

We, the undersigned, hereby certify that the clarification is an integral part of the document and the alterations set out in clarification have been incorporated in our tender document.
Signed
Tenderer
Date