

KENYA ELECTRICITY GENERATING COMPANY PLC

KGN~TANA~010~2024

RFx: 5000016000

TENDER FOR SUPPLY OF LIFTING EQUIPMENT FOR TANA POWER STATION.

(WOMEN ENTERPRISE ONLY)

19th December, 2024

CLARIFICATION NO.5

In accordance with the "Tender for supply of Lifting Equipment for Tana Power Station," KenGen hereby issues, Clarification No.5

No.	Bidder Clarification	KenGen Response
1	Item 17: Hydraulic hand pallet stacker Picture Manual or Electric	Manual
2	Item 18: Electric chain hoist Do you need an electric trolley? If yes, beam weight? Do you need the festoon system? If yes, which length (m) — Do you have a drawing? For the pendant control, do you need system with cable or wireless? If cable, which length (m)?	 Trolley: Motorized trolley (Electric) Trolley flange range: 3.94" to 7.02" Festoon system: Not needed (See attached drawing as guide) Pendant control: Wired Cable length: Atleast 6 Metres

ACKNOWLEDGEMENT OF CLARIFICATION-NO-5

Signed	
Tenderer	
Date	

We, the undersigned hereby certify that the Clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.