



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-SONDU-012-2024

RFx: 5000014982

TENDER FOR SUPPLY AND DELIVERY OF GOVERNOR STRATEGIC SPARES FOR SANG'ORO POWER STATION.

(CITIZEN CONTRACTORS)

Date: 9th April, 2024

Clarification No.1

In accordance with the Tender for Supply and Delivery of Governor Strategic Spares for Sang'oro Power Station, KenGen hereby issues clarification No.1

NO	CLARIFICATION SOUGHT	KenGen RESPONSE
1.	<p>As interested and participating bidders in the above-referenced tender, we would like to kindly request for a clarification below:</p> <p>Please share the Clear Images of Existing Nameplates for the Accumulator Bladder and Gear Pump.</p>	<p>Accumulator bladder; please supply as per the technical specifications on page 58 of the Tender Document</p> <p>Gear Pump; please supply as per the technical specifications on Page 59 of the Tender Document</p>
2.	<p>The tender calls for a 300L bladder accumulator, but bladder accumulators only go up to 200L as per the specs attached. Piston accumulators on the other hand exceed 200L.</p> <p>Kindly clarify if the tender calls for a bladder or piston accumulator and the if the size is 130L or 300L.</p>	<p>The tender calls for an accumulator bladder with a nominal volume of 100 litres per bladder.</p>

BIDDER'S ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the **clarification** is an integral part of the document and the alterations set out in Addendum have been incorporated in our tender document.

Signed

Tenderer

Date