



KenGen

KENYA ELECTRICITY GENERATING COMPANY PLC

**TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF
ENGINES BIG END BEARING TEMPERATURE SENSOR FOR KIPEVU III POWER
STATION
(CITIZEN CONTRACTORS)**

KGN-KIP-01-2023

17th March 2023

CLARIFICATION NO. 1

In accordance with the “Tender for supply, installation, testing and commissioning of engines big end bearing temperature sensor for Kipevu iii power station” KenGen hereby issues

Clarification No.1;

No.	Bidder's Question	KenGen's Response
	Price Schedule 1 à “Supply of Signal processing units (SPU) for Sentry 200” quantity mentioned is 6. It's supposed to be 3 since its 3 engines. Check and confirm	Confirmed that each engine will require two (2) pcs signal processing units (SPU). It's supposed to be six (6) pcs for the three (3) engines.
	Price Schedule 2 à “Supply of Signal processing units (SPU) for Sentry 200” quantity mentioned is 10. It's supposed to be 4 since its 4 engines. Check and confirm	Confirmed that each engine will require two (2) pcs signal processing units (SPU). It's supposed to be eight (8) pcs for the four (4) engines plus two (2) pcs spare SPU.
	Price Schedule 2 à “All required wiring to be mounted on the engine and cabling to the local display unit/ stand-alone cabinet” Qty 1 instead of quantity 2	<i>Price Schedule 2 amended. Please refer to addendum No. 5 on our website.</i>
	Price Schedule 2à Missing “Installation and Commissioning of the Engine Big End Bearing Temperature Sensors (4 Engines)”. Please check and Confirm	Confirmed that “Installation and Commissioning of the Engine Big End Bearing Temperature Sensors (4 Engines)” is not a deliverable in this schedule.

	Price Schedule 2à Missing “Installation of the Big End Bearing Control System and Integration onto a standalone display unit system at the control room”. Please check and confirm	Confirmed that “Installation of the Big End Bearing Control System and Integration onto a standalone display unit system at the control room is not a deliverable” in this schedule.
	We would also like to request for extension of Tender up to 15th of March to allow us enough time to prepare and submit competitive bind.	<i>Extension granted to 23rd March 2023. Please refer to Addendum No. 5 on our website</i>

ACKNOWLEDGEMENT OF CLARIFICATION NO 1.

We, the undersigned hereby certify that the Clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....