



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-SONDU-015-2024

RFx: 5000015229

**TENDER FOR SUPPLY AND DELIVERY OF PLANT SYSTEM STRATEGIC SPARES FOR SANG'ORO POWER STATION  
(CITIZEN CONTRACTORS)**

Date: 12<sup>th</sup> June, 2024

**Clarification No 2.**

In accordance with the “Tender For Supply and Delivery of Plant System Strategic Spares for Sang’oro Power Station ”KenGen issues **Clarification No 2.**as follows;

NO	CLARIFICATION SOUGHT	KENGEN'S RESPONSE
1	<p>According to the Special Conditions of Contract, Section VII - Special Conditions of Contract Pg. No. 85 – Tender Document, “The period of validity of the Warranty shall be: [24 months] from date of acceptance”.</p> <p>However, the potential manufacturers are offering a warranty of 12 months. This is in accordance with clause 28 of the tender document.</p> <p>Kindly advise</p>	<p>(12 to 24) Months Warranty is acceptable</p>
2	<p>According to Section III – Evaluation and Qualification Criteria, Stage 1: Mandatory Requirements, MR 17, Pg. No. 30, you have indicated that the bidder to “Provide proof of Authorization from manufacturer by providing a Duly filled, signed and stamped Manufacturer’s Authorization Letter (if bidder is not the manufacturer).”</p> <p>Some of the potential manufacturers have mandated their authorized regional distributors to sign off on documents such as the manufacturer’s authorization letter with provision of a letter stating that they are their authorized distributor.</p> <p>Kindly advise.</p>	<p>Provide the signed off manufacturer’s authorization letter and a letter stating they are mandated as regional distributors. KenGen shall however conduct due diligence to confirm authenticity of the submitted documents</p>
3	<p>According to Clarification 1 dated 23rd May, 2024; you have indicated that the “Proposed TURCK model must conform to all technical specifications of the MS22-Ri” and that the “Proposed TURCK model must conform to all technical specifications of the MS24-R”</p> <p>However, our manufacturer has informed us that the proposed TURCK</p>	<p>Turck MS22-Ri and Turck MS24-R remain the preferred models. However, due to the challenge mentioned, the TURCK IM21-14-CDTRI is an acceptable alternative</p>

	<p>model will not FULLY conform to ALL technical specifications of MS22-Ri and MS24-R because of improvement in technology as they can now offer an excellent, state-of-the-art solution from the current ones. Moreover, the manufacturer has been affected by the discontinuation of a component used in the TURCK models required. Kindly advise on what alternative model can be provided.</p>													
4	<p>Kindly give us the below details for all the magnetic flow meters (items 1-4 of the price schedule):</p> <ol style="list-style-type: none"> <li>1. flow rates             <ol style="list-style-type: none"> <li>a. Minimum</li> <li>b. Maximum</li> <li>c. Operating</li> </ol> </li> <li>2. line pressure             <ol style="list-style-type: none"> <li>a. Minimum</li> <li>b. Maximum</li> <li>c. Operating</li> </ol> </li> </ol> <p>We have assumed that:</p> <ol style="list-style-type: none"> <li>1. The process fluid is water but please mention if its clean or river (with dirt/solids). This will affect the lining of the meters proposed</li> <li>2. The Power Supply is AC</li> </ol>	<p>The clarifications are clearly specified in the clarifications No 1 shared earlier.</p> <table border="1" data-bbox="817 465 1519 815"> <tr> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>Flow rates</td> <td>Refer to clarification no.1,( item 2 and 3). Datasheets should guide</td> </tr> <tr> <td>2</td> <td>Line Pressure</td> <td>Refer to clarification no.1,( item 2 and 3). Datasheets should guide</td> </tr> <tr> <td>3</td> <td>Power supply</td> <td>24VDC is preferred; Refer to clarification no.1</td> </tr> </table>				1	Flow rates	Refer to clarification no.1,( item 2 and 3). Datasheets should guide	2	Line Pressure	Refer to clarification no.1,( item 2 and 3). Datasheets should guide	3	Power supply	24VDC is preferred; Refer to clarification no.1
1	Flow rates	Refer to clarification no.1,( item 2 and 3). Datasheets should guide												
2	Line Pressure	Refer to clarification no.1,( item 2 and 3). Datasheets should guide												
3	Power supply	24VDC is preferred; Refer to clarification no.1												

**BIDDER’S ACKNOWLEDGEMENT OF CLARIFICATION NO.2**

We, the undersigned hereby certify that the **clarification** is an integral part of the document and the alterations set out in Addendum have been incorporated in our tender document.

Signed .....

Tenderer .....

Date .....